



- NOTES:**
- FOR PUMP SPECIFICATIONS REFER TO PUMP DESIGN BRIEF.
  - THE CONTRACTOR AND SUPPLIER SHALL COORDINATE POWER REQUIREMENTS PRIOR TO ORDERING OF THE PUMP STATION.
  - MAXIMUM OF 3 FEET OF EARTH COVER IN RESIDENTIAL LAWN.
  - REFER TO THE PUMP STATION DESIGN BRIEF OR CONSULT THE DESIGNER ON THE NEED FOR A WEEP HOLE OR NOT.
  - CONTROL PANE WITH AUDIBLE AND VISUAL ALARM MUST BE MOUNTED ON SUPPORTS SET IN THE GROUND AT THE PUMP STATION, ON THE HOUSE OR IN THE MECHANICAL ROOM.

**SPECIAL NOTE:**

- ALL PIPING WITHIN PUMP STATION AND VALVE PIT TO BE 2" SCH 80 PVC UNLESS OTHERWISE SPECIFIED

- SPECIFICATIONS:**
- TANK TO MEET ASTM C1227-13 AND ASTM C890-13 REQUIREMENTS
  - MID SEAM CONSTRUCTION
  - JOINT SEALANT: 1" NOMINAL DIAMETER OR EQUIVALENT BUTYL RUBBER MASTIC SEALANT CONTINUOUS IN JOINT.
  - ALL DIMENSIONS SHOWN ARE PER ONSITE SEPTIC SOLUTIONS, LLC PRODUCTS 2017.

**2,000 GALLON MID SEAM 4" TOP & BOTTOM PRECAST CONCRETE DUPLEX PUMP STATION**

1/2"=1'-0"



BUSINESS PARK AT CAMBRIDGE  
CAMBRIDGE, VT. 05444  
paul@onsitesepoticsolutions.biz  
TEL. 802-644-5500