



**NOTES:**

1. PUMP SHALL BE CAPABLE OF XX GPM @ XX TDH.
2. THE CONTRACTOR AND SUPPLIER SHALL COORDINATE POWER REQUIREMENTS PRIOR TO ORDERING OF THE PUMP STATION.
3. IF REQUESTED THIS PUMP STATION CAN BE SETUP AS A DUPLEX PUMP STATION.
4. PER ONSITE SEPTIC SOLUTIONS, LLC (SUPPLIER), THE TOP OF THIS TANK SHALL BE BURIED NO DEEPER THAN 3 FEET BELOW FINISHED GRADE. IF A DEEPER BURIAL DEPTH IS NEEDED SEE SUPPLIER FOR SIMILAR TANKS THAT CAN BE BURIED DEEPER THAN 3 FEET.
5. REFER TO THE PUMP STATION DESIGN BRIEF OR CONSULT THE DESIGNER ON THE NEED FOR A WEEP HOLE OR NOT.

**SPECIFICATIONS:**

1. TANK TO MEET ASTM C-478 REQUIREMENTS
2. TOP SEAM CONSTRUCTION
3. NOT DESIGNED FOR TRAFFIC AREAS
4. ALL DIMENSIONS SHOW ARE PER ONSITE SEPTIC SOLUTIONS, LLC PRODUCTS 2017.

**48" I.D PUMP STATION**

1/2"=1'-0'



BUSINESS PARK AT CAMBRIDGE  
CAMBRIDGE, VT. 05444  
paul@onsitesepoticsolutions.biz  
TEL. 802-644-5500